

# ENTSO-E Ten-Year Network Development Plan

Trends in the European Energy Industry  
TOP EXPO CZ, 24<sup>th</sup> May 2011 Prague

Andrew Kasembe  
Head of Department, Transmission System Development

# Contents

- Highlight from the Pilot TYNDP
- 2012 TYNDP Process
- SO&AF 2011
- ČEPS Grid Development Investment Plan
- Conclusions



# Highlights from the Pilot TYNDP



## ENTSO-E Tasks defined by Regulation (EC) 714/2009

- A non-binding Ten Year Network Development Plan incl. a European generation adequacy outlook, every 2 years.
- Annual summer/winter generation adequacy outlooks.
- And R&D Plans, common network operation tools, and of course drafting network codes.




## Main drivers highlighted from the Pilot TYNDP

- Connection of new generation: RES in the North, conventional generation in the Northern and Eastern part
- Pumped storage in the South
- Security of supply in the global CEE region
- Ageing and obsolescence of the current grid infrastructure



# Pilot TYNDP delivered



Main drivers for investment in new or refurbished power lines






# Pilot TYNDP delivers

... an impressive investment effort ....

Investment costs of transmission projects of European Significance, period 2010 - 2014



**Total ENTSO-E 23 to 28 bn€**




# 2012 TYNDP Process






# 2012 TYNDP process



# RgIP & TYNDP 2012 Deliverables




# Scenario outlook & Adequacy Forecast (SO&AF) 2011



# SO&AF EU2020 scenario shows RES increase and beginning decrease of fossil fuel generation

Net generation capacities, all ENTSO-E, January 7 p.m. forecasts



**SO&AF EU2020 scenario** shows also Load increase at the average rate of 1,5%

[GW]	2011	2015	2016	2020	2025
<b>January</b>	531	557	565	600	637
<b>July</b>	425	450	457	489	523

Table 2.3:  
ENTSO-E load forecast for Scenario B

[%]	2011 to 2015	2015 to 2020	2020 to 2025
<b>January</b>	1.2	1.5	1.2
<b>July</b>	1.5	1.7	1.4

Table 2.4:  
ENTSO-E average load increase rate for Scenario B






Figure 2.1:  
ENTSO-E consumption forecast for the Scenario EU 2020




# Adequacy methodology – RES effects on non-usable capacity







# System effects of shutting down several power plants



# SO&AF – based sensitivity assessments of German moratorium

## ENTSO-E nuclear forecasts under Scenario A and B with 7 GW less



**Taking into account the entire ENTSO-E generating capacity, the difference is slight.**

Data extracted from: <https://www.entsoe.eu/system-development/soaf-2011-2025/>



# ČEPS grid development investment plan








## Factors influencing Grid Development (2)

### ▪ Distribution Companies

- Significant consumption growth – new node (Ostrava region)
- Increase of consumption (existing nodes)




## Factors influencing Grid Development (3)

### External influence

- Support of European Internal Market
- Integration of RES – Germany, transits and loop-flows
- Coordination of grid investments in the region, installation PST “DE-PL”

Schéma sítí 400 a 220 kV







# Grid connection applications till 2030

## Increase of power generation

- Nuclear power plants: up to 5100 MW
- Lignite power plants: 2024 MW
- CCGT: 4585 MW
- Wind power plants: 140
- Pump storage hydro power plants: 1000 MW
- Photovoltaic units: 41 MW      **Σ 12890 MW**



Increase of consumption: **1834 MW**






# TRANSMISSION SYSTEM OF CZECH REPUBLIC YEAR 2020



- EXISTING LINE/SUBSTATION 400kV (2010)
- EXISTING LINE/SUBSTATION 220kV (2010)
- NEW LINE/SUBSTATION (2015–2020) – PLANNED
- NEW LINE/SUBSTATION (2015–2020) – UNDER CONSIDERATION
- REINFORCEMENT/UPGRADE (2015–2010) – PLANNED
- REINFORCEMENT/UPGRADE (2015–2020) – UNDER CONSIDERATION
- MEASURE OF PREVIOUS TIME HORIZON (2010–2015)

DE  
50Hertz Transmission

PL  
PSE Operator




AT  
VERBUND APG

SK  
SEPS

# TRANSMISSION SYSTEM OF CZECH REPUBLIC YEAR 2025



- EXISTING LINE/SUBSTATION 400kV (2010)
- EXISTING LINE/SUBSTATION 220kV (2010)
- NEW LINE/SUBSTATION (2020-2025) - PLANNED
- NEW LINE/SUBSTATION (2020-2025) - UNDER CONSIDERATION
- REINFORCEMENT/UPGRADE (2020-2025) - PLANNED
- REINFORCEMENT/UPGRADE (2020-2025) - UNDER CONSIDERATION
- MEASURE OF PREVIOUS TIME HORIZON (2010-2020)



# Conclusions



## Conclusions:

- Harmonization of generation evolution with grid infrastructure reinforcements plans.
- Legal and Regulatory frameworks.
- ENTSO-E investment costs within next four years ranging from 23 to 28 bn€. Only CCE region about 8 bn€.
- In the time horizon 2011 – 2030 ČEPS has to invest more than € 2.6 billions in new infrastructure.
- Coordination of planning and operational measure needed.
- All relevant stakeholders should take part in the process (mitigate uncertainties, harmonize the legal and regulatory framework, and enhance social acceptance of transmission assets).





# Well unbundled connectivity

**Andrew KASEMBE**

Head of Department – Transmission System Development &  
Convenor ENTSO-E RG Continental Central East

ČEPS, a.s  
Elektrárenská 774/2  
Prague 10

[kasembe@ceps.cz](mailto:kasembe@ceps.cz)

[www.ceps.cz](http://www.ceps.cz)

